

2024 Consumer Confidence Report

Water System Name: RIVERVIEW WATER ASSOCIATION

Report Date: March 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: is considered most vulnerable to the following activities not associated with any detected contaminants: ACTIVITY #1 Recreational surface water ACTIVITY #2 ACTIVITY #3

Your water comes from 2 source(s): WELL 1 BEACON HARBOR and WELL 2 END OF WILLOW RD

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board Annual Member Meeting will be held at BIMID Hall at 3085 Stone Rd, Bethel Island on June 7, 2025 at 10:00 am Go to riverviewwater.com for more information.

For more information about this report, or any questions relating to your drinking water, please call (925)212-2379 and ask for Patty Martin.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2024)	10	6	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	10	0.10	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	311	268 - 354	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	277	216 - 338	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022)	5	2 - 8	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Barium (mg/L)	(2022)	0.19	0.16 - 0.21	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Selenium (ug/L)	(2022)	8	5 - 10	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	433	327 - 538	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2022)	85	70 - 100	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2022)	220	160 - 280	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2022)	2005	1750 - 2260	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	93.5	53.0 - 134	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	1155	990 - 1320	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2022)	2	1.7 - 2.3	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2022)	220	160 - 280	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	59	47 - 71	n/a	n/a
Magnesium (mg/L)	(2022)	32	24 - 39	n/a	n/a
pH (units)	(2022)	8	7.9 - 8.1	n/a	n/a
Alkalinity (mg/L)	(2022)	205	200 - 210	n/a	n/a
Aggressiveness Index	(2022)	12.5	n/a	n/a	n/a
Langelier Index	(2022)	0.6	0.5 - 0.6	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at

risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Riverview Water Association* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Chloride				n/a
Manganese				Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.
Specific Conductance				The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCLs were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.
Total Dissolved Solids				The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2024 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 1 BEACON HARBOR and the WELL 2 END OF WILLOW RD of the RIVERVIEW WATER ASSOCIATION water system in December, 2002.

WELL 1 BEACON HARBOR - is considered most vulnerable to the following activities not associated with any detected contaminants:

ACTIVITY #1 Recreational surface water

ACTIVITY #2

ACTIVITY #3

WELL 2 END OF WILLOW RD - is considered most vulnerable to the following activities not associated with any detected contaminants:

ACTIVITY #1 Recreational surface water

ACTIVITY #2

ACTIVITY #3

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

-The Assessment has not been completed. Contact the local DDW district office or the water system to find out when the Assessment is scheduled to be done.

-The source is not active. It may be out of service, or new and not yet in service.

-The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Riverview Water Association

Analytical Results By FGL - 2024

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			6	10
3507 Willow Road	STK2454508-3	ug/L				2024-09-23	ND		
3559 Willow Road	STK2454508-4	ug/L				2024-09-23	6		
3605 Willow Road	STK2454508-2	ug/L				2024-09-26	ND		
3611 Willow Road	STK2454508-1	ug/L				2024-09-25	ND		
3667 Willow Road	STK2454508-5	ug/L				2024-09-22	ND		
3717 Willow Road	STK2454507-3	ug/L				2024-09-26	ND		
3753 Willow Road	STK2454507-2	ug/L				2024-09-23	ND		
3783 Willow Road	STK2454507-5	ug/L				2024-09-21	ND		
3803 Willow Road	STK2454507-1	ug/L				2024-09-22	8		
3861 Willow Road	STK2454507-4	ug/L				2024-09-25	ND		
Copper		mg/L		1.3	.3			0.10	10
3507 Willow Road	STK2454508-3	mg/L				2024-09-23	0.10		
3559 Willow Road	STK2454508-4	mg/L				2024-09-23	0.08		
3605 Willow Road	STK2454508-2	mg/L				2024-09-26	0.06		
3611 Willow Road	STK2454508-1	mg/L				2024-09-25	ND		
3667 Willow Road	STK2454508-5	mg/L				2024-09-22	0.05		
3717 Willow Road	STK2454507-3	mg/L				2024-09-26	0.10		
3753 Willow Road	STK2454507-2	mg/L				2024-09-23	0.07		
3783 Willow Road	STK2454507-5	mg/L				2024-09-21	ND		
3803 Willow Road	STK2454507-1	mg/L				2024-09-22	0.11		
3861 Willow Road	STK2454507-4	mg/L				2024-09-25	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			311	268 - 354
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	268		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	354		
Hardness		mg/L		none	none			277	216 - 338
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	216		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	338		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			5	2 - 8
WELL 1 BEACON HARBOR	STK2252807-1	ug/L				2022-09-12	2		
WELL 2 END OF WILLOW RD	STK2252808-1	ug/L				2022-09-12	8		
Barium		mg/L	2	1	2			0.19	0.16 - 0.21
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	0.16		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	0.21		
Selenium		ug/L	50	50	30			8	5 - 10
WELL 1 BEACON HARBOR	STK2252807-1	ug/L				2022-09-12	5		
WELL 2 END OF WILLOW RD	STK2252808-1	ug/L				2022-09-12	10		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			433	327 - 538
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	327		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	538		
Iron		ug/L		300	n/a			85	70 - 100
WELL 1 BEACON HARBOR	STK2252807-1	ug/L				2022-09-12	70		

WELL 2 END OF WILLOW RD	STK2252808-1	ug/L				2022-09-12	100		
Manganese		ug/L		50	n/a			220	160 - 280
WELL 1 BEACON HARBOR	STK2252807-1	ug/L				2022-09-12	160		
WELL 2 END OF WILLOW RD	STK2252808-1	ug/L				2022-09-12	280		
Specific Conductance		umhos/cm		1600	n/a			2005	1750 - 2260
WELL 1 BEACON HARBOR	STK2252807-1	umhos/cm				2022-09-12	1750		
WELL 2 END OF WILLOW RD	STK2252808-1	umhos/cm				2022-09-12	2260		
Sulfate		mg/L		500	n/a			93.5	53.0 - 134
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	134		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	53.0		
Total Dissolved Solids		mg/L		1000	n/a			1155	990 - 1320
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	990		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	1320		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			2.0	1.7 - 2.3
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	2.3		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	1.7		
Manganese		ug/L		NS	n/a			220	160 - 280
WELL 1 BEACON HARBOR	STK2252807-1	ug/L				2022-09-12	160		
WELL 2 END OF WILLOW RD	STK2252808-1	ug/L				2022-09-12	280		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			59	47 - 71
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	47		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	71		
Magnesium		mg/L			n/a			32	24 - 39
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	24		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	39		
pH		units			n/a			8.0	7.9 - 8.1
WELL 1 BEACON HARBOR	STK2252807-1	units				2022-09-12	8.1		
WELL 2 END OF WILLOW RD	STK2252808-1	units				2022-09-12	7.9		
Alkalinity		mg/L			n/a			205	200 - 210
WELL 1 BEACON HARBOR	STK2252807-1	mg/L				2022-09-12	210		
WELL 2 END OF WILLOW RD	STK2252808-1	mg/L				2022-09-12	200		
Aggressiveness Index					n/a			12.5	12.5 - 12.5
WELL 1 BEACON HARBOR	STK2252807-1					2022-09-12	12.5		
WELL 2 END OF WILLOW RD	STK2252808-1					2022-09-12	12.5		
Langelier Index					n/a			0.6	0.5 - 0.6
WELL 1 BEACON HARBOR	STK2252807-1					2022-09-12	0.6		
WELL 2 END OF WILLOW RD	STK2252808-1					2022-09-12	0.5		